



 Delhi Jal Board No.DJB/QCLTYR/PD/240910	DELHI JAL BOARD (GOVT. OF N.C.T. DELHI) QUALITY CONTROL LABORATORY, TRANS YAMUNA REGION TAHIRPUR DELHI-110093	 एक कदम स्वच्छता की ओर
	 भारतीय मानक प्युरो BUREAU OF INDIAN STANDARDS LICENCE No- CRO/QM/L-8004274 as per IS/ISO 9001:2015	

NO: DJB/ACWA(TYR)/2024.....

DATE:- 28-09-2024

Analysis report of DJB water samples collected from (1) Inlet, (2) Outlet of M/S KERALA EDUCATION SOCIETY SENIOR SECONDARY SCHOOL, POCKET A-3, MAYUR VIHAR PHASE-III, DELHI-110096, for drinking purpose.

Ref. No. KESS/Water testing/328/2024, dated : - 24.09.2024
 Challan No: - 160, dated: - 24.09.2024



Date of collection : 26-09-2024

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	...	...	-	Clear	Clear
2.	Odour	...	...	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	3.06	2.91
4.	pH Value	6.5-8.5	---	-	7.5	7.6
5.	Electrical Conductivity	---	---	µs/cm	236	240
6.	Total Dissolved Solids	500	2000	mg/l	133	156
B.	Chemical Examination					
7.	P th Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	88	90
9.	Total Hardness	200	600	mg/l	98	100
10.	Calcium as (Ca)	75	200	mg/l	28.8	28.0
11.	Magnesium as (Mg)	30	100	mg/l	6.24	7.20
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	...	...	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	2.48	2.66
15.	Sulphate	200	400	mg/l	28.75	28.94
16.	Chloride	250	1000	mg/l	12	12
17.	Fluoride	1.0	1.5	mg/l	0.04	0.05
18.	Total Iron	1.0	NR	mg/l	0.10	0.08
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	0.50	0.20
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conform BIS: 10500-2012 and can be considered fit for drinking purpose.

(B.K Verma) ACWA(TYR) Asstt. Chief Water Analyst D.J.B. Govt. of N.C.T. of Delhi Quality Control Zonal Laboratory (TYR) Tahirpur Unshad Garden, Delhi-93	(A.G. S. ...) BACTERIOLOGIST Principal Kerala Education Society School Govt. AIDED-Linguistic Minority Mayur Vihar-III, Delhi-110096	(Gulsh Jainar) CHEMIST Manager Kerala Education Society School Govt. AIDED-Linguistic Minority Mayur Vihar-III, Delhi-110096
---	---	---

MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
SHAHDARA (SOUTH) ZONE
419 1st Floor, UDYOG SADAN
PATPARGANJ INDUSTRIAL AREA DELHI-110092

No. : DHO/Shd.(S)/2025/D- 867

Date: 22/4/25


School Health Certificate

- | | |
|------------------------------|---|
| 1. Name of School | : Kerala Education Society Sr. Sec. School |
| 2. Location of the School | : Pocket A-3, Mayur Vihar Phase-3, Delhi-96 |
| 3. Timing of School | : 7:50 A.M to 1:50 P.M |
| 4. No. of Students | : 795 (Boys- 431, Girls-364) |
| 5. No. of Staff | : 26 |
| 6. No. of Rooms | : 55 |
| 7. No. of Doors in each room | : Provided |
| 8. No. of Fans in each room | : Provided |
| 9. No. of Toilets for Boys | : 19 |
| 10. No. of Toilets for Girls | : 32 |
| 11. Building Structure | : Pucca |
| 12. Drinking Water | : DJB Water Supply |
| 13. Electricity | : BSES |

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

The Principal
Kerala Education Society Sr. Sec. School
Pocket A-3, Mayur Vihar Phase-3, Delhi-110096


Deputy Health Officer
Shahdara (South) Zone

DEPUTY HEALTH OFFICER
MUNICIPAL CORPORATION OF DELHI
SHAHDARA (SOUTH) ZONE


Principal

Kerala Education Society School
Govt. AIDED-Linguistic Minority
Mayur Vihar-III, Delhi-110096


Manager

Kerala Education Society School
Govt. AIDED-Linguistic Minority
Mayur Vihar-III, Delhi-110096